

**APPLICATION FOR PERMIT
TO APPROPRIATE THE PUBLIC WATERS OF THE STATE OF NEVADA**

Date of filing in State Engineer's Office..... DEC 18 1979

Returned to applicant for correction.....

Corrected application filed.....

Map filed..... May 24 , 1978 under 35257

The applicant..... St. Mary's Hospital
235 West Sixth Street....., of..... Reno.....
Street and No. or P.O. Box No. City or Town
Nevada 89503....., hereby make application for permission to appropriate the public
State and Zip Code No.

waters of the State of Nevada, as hereinafter stated. (If applicant is a corporation, give date and place of incorporation; if a copartnership or association, give names of members.)..... corporation, September 14, 1912,
Reno, NV

1. The source of the proposed appropriation is..... underground
Name of stream, lake or other source.

2. The amount of water applied for is..... 1.50.....second-feet
One second-foot equals 448.83 gals. per min.

(a) If stored in reservoir give number of acre-feet..... acre-feet

3. The water to be used for..... emergency source of supply for the hospital
Irrigation, power, mining, manufacturing, domestic, or other use. Must limit to one use.

4. If use is for:

(a) Irrigation (state number of acres to be irrigated).....

(b) Stockwater (state number and kinds of animals to be watered).....

(c) Other use (describe fully under "No. 12. Remarks").....

(d) Power:

(1) Horsepower developed.....

(2) Point of return of water to stream.....

5. The water is to be diverted from its source at the following point: NE $\frac{1}{4}$ NW $\frac{1}{4}$ Section 11, T19N,
R19E, MDB&M (SW corner of Elm Street and West Street in Reno, NV)
with the point of diversion bearing North 73° 14' 44" West a distance
Describe as being within a 40-acre subdivision of public survey, and by course and distance to a section corner. If on unsurveyed land,
of 2,487.38 feet to the northwest corner of said section 11.
it should be stated.

6. Place of use St. Mary's Hospital (235 West Sixth Street, Reno, NV
Describe by legal subdivision, if on unsurveyed land it should be so stated.
89503) being a portion of the NE $\frac{1}{4}$ of the NW $\frac{1}{4}$ of Section 11, T19N,
R19E, MDB&M.

7. Use will begin about January 1 and end about December 31, of each year.
Month and Day Month and Day

8. Description of proposed works. (Under the provisions of NRS 535.010 you may be required to submit plans and specifications of your diversion or storage works.)..... gravel packed water well equipped
with a turbine well pump and motor and necessary electrical and con-
State manner in which water is to be diverted, whether by dam or other works, whether through pipes, ditches, flumes, or other conduits.
trol equipment. Source will be connected to the existing hospital
water system.

9. Estimated cost of works.....\$93,000.....
10. Estimated time required to construct works.....12 months.....
11. Estimated time required to complete the application to beneficial use.....5 years.....
12. Remarks: For use other than irrigation or stock watering, state number and type of units to be served or annual consumptive use.

The well source is to be used for an emergency source (in the event of a failure or non-usability of Sierra Pacific Power Company Water system) for a 360-bed hospital. Use would be on an emergency/intermittent use (except for periodic operational system checks) and the annual consumptive use would be minimal. It is assumed for permit purposes that the annual consumptive use could be 100 acre feet per year. Use original mylar map from Filing Serial Number 35257 for this application. No changes are required.

Applicant.....St. Mary's Hospital.....

By.....s/ George W. Ball, Jr.
George W. Ball, Jr., P.E., Cert. #409
28 Vine Street
Reno, NV 89503

Compared.....lp/ga.....gk/ja.....

APPROVAL.....OF STATE ENGINEER

This is to certify that I have examined the foregoing application, and do hereby grant the same, subject to the following limitations and conditions:

This permit is issued subject to existing rights. It is understood that the amount of water herein granted is only a temporary allowance and that the final water right obtained under this permit will be dependent upon the amount of water actually placed to beneficial use. It is also understood that this right must allow for a reasonable lowering of the static water level. This well shall be equipped with a two (2) inch opening for measuring depth to water. If the well is flowing, a valve must be installed and maintained to prevent waste. A totalizing meter must be installed and maintained in the discharge pipeline near the point of diversion and accurate measurements must be kept of water placed to beneficial use. The totalizing meter must be installed before any use of water begins, or before the Proof of Completion of Work is filed. This source is located within an area designated by the State Engineer, pursuant to NRS 534.030. The State retains the right to regulate the use of the water herein granted at any and all times.

The amount of water to be appropriated shall be limited to the amount which can be applied to beneficial use, and not to exceed.....1.5.....cubic feet per second, but not to exceed.....

32.6 million gallons annually.

Actual construction work shall begin on or before.....February 6, 1981.....

Proof of commencement of work shall be filed before.....March 6, 1981.....

Work must be prosecuted with reasonable diligence and be completed on or before.....February 6, 1982.....

Proof of completion of work shall be filed before.....March 6, 1982.....

Application of water to beneficial use shall be made on or before.....February 6, 1983.....

Proof of the application of water to beneficial use shall be filed on or before.....March 6, 1983.....

Map in support of proof of beneficial use shall be filed on or before.....

Commencement of work filed.....IN TESTIMONY WHEREOF, I.....WILLIAM J. NEWMAN.....
Completion of work filed.....State Engineer of Nevada, have hereunto set my hand and the seal of
Proof of beneficial use filed.....my office, this.....6th.....day of.....AUGUST.....

Cultural map filed.....
Certificate No.....Issued.....A.D. 19.....80.....

CANCELLED APR 7 1983

OF APPLICANT TO COMPLY WITH THE PROVISIONS OF NRS 534.030